




ਦਫਤਰ ਸਿਵਲ ਸਰਜਨ, ਬਠਿੰਡਾ।
ਆਈ.ਡੀ.ਐਸ.ਪੀ./ਨੈਸ਼ਨਲ ਵੈਕਟਰ ਬੋਰਨ ਡਜੀਜ ਕੰਟਰੋਲ
ਪ੍ਰੋਗਰਾਮ
ਫੋਨ: ਨੰ: 0164-2212501,(0164-2240255
ਈ.ਮੇਲ nvbdcpbathinda@gmail.com)



No.NVBDCP/Tech/22/ 1165

Dated: 09/12/22

It is certified that as per request of the Principal, THE SANSKAR SCHOOL Talwandi Sabo District Bathinda for granting Health and Sanitation Certificate. Civil Surgeon, Bathinda has instructed to SMO Talwandi sabo vide letter no Malaria/tech/2022/1154 dated 08.12.2022 to inspect the premises for giving physical verification report. As per physical verification report conducted on vide their letter no Malaria/tech/2022/1215 dated 09.12.2022, the premises of above said institution is found to be hygienically neat and clean. Drinking water of this institute is also found fit for human consumption after testing report by the District Water testing Lab. Bhagu Road, Bathinda vide their letter no. DWTL/BTI/2122/2223/00607 Dated 29.11.2022. This certificate is valid for one year.


Distt. Epidemiologist (NVBDCP)
O/o Civil Surgeon, Bathinda.

Distt. Programme Officer, NVBDCP
Civil Surgeon Office
Bathinda


DISTRICT WATER TESTING LABORATORY, BATHINDA

Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

TEST REPORT						
Name & Address of Customer : Principal The Sanskaar School Talwandi Sabo			Customer Reference No.		No : TSS/2022-23/142 Dated : 22/11/2022	
			Sample Submitted by		Sh.Harman Singh	
			Date of Sample Receipt		22/11/2022	
			Analysis Starting Date		24/11/2022	
			Analysis completion Date		29/11/2022	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC9883220000017F	Sample Type :	Water			
Test Report No.:	DWTL/BTI/2122/2223/00607	Date of Issue :	29/11/2022			
Registration no.:	DWTL/BTI/2122/REG2223/01369	Condition of Sample :	Unsealed			
Source :	Not Mentioned	Quantity/Type of Bottle:	1000 ml / NA			
Scheme :	Not Mentioned	Location/Depth :	Water Sample from The Sanskaar School Talwandi Sabo / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Talwandi Sabo	District :	Bathinda			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.16	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	< 5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	1290	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	1.14	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	344	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	464	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	82	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	63	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	78	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory,
Bathinda

----- End of the Test Report -----